

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. U2653223S30591637

Dated: 14/07/2025

It is certified that an inspection team headed by Ankit Chauhan, Lab In charge, District Level Water Analysis Laboratory, Sitapur (Name of officers with designation) from UP Jal Nigam (Rural) Sitapur (Name of Department/office) Inspected the APS International school, Gondlamau Sitapur, Uttar Pradesh 261303 (Name & Address of the school) on 08-07-2025 (Date of inspection) and on the basis of water test report (Attached) Report no: U2653223S30591637 dated 11-07-2025 of District Level Water Analysis Laboratory, Sitapur (PHED) lab certified that the APS International school, Gondlamau Sitapur (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T.Govt.

Note:

This certificate is valid till 01 Year from date of issue. In case, if there is any change in Drinking Source /gone under maintenance before Expiry of certificate, then this certificate will be no more valid. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Sitapur.


Executive Engineer
Division Office
Jal Nigam (Rural)
Sitapur

Signature with Seal.....

Name RAJEEV KUMAR

Designation EXECUTIVE ENGINEER

Name & Address of the office/Department

Arya Nagar Water Tank Sitapur

o/c Anand


Principal
APS International School
Kuchlai Gopalpur Bhatta Sidhauli
Sitapur

To

APS International school

Village Kuchlail Grampanchayat Kuchlail Sitapur, Uttar Pradesh 261303

(Name & Address of the Institution)


APS International School
Director/Manager

Jal Jeevan Mission

Har Ghar Jal



District Level Water Analysis Laboratory , U.P Jal Nigam (Rural), Sitapur

Arya Nagar near water tank, Sitapur Pin- 261001 (Test Address only)

Test report

Sample
Id:

U2653223530591637

User Information

Name	APS INTERNATIONAL SHOOOL	Mobile	9005709301
Email	APSINTERNATIONALSCHOOL4@GMAIL.COM	Pin Code	261303
Full Address	Village- Kuchilal , Gram Panchayat- Kuchilal, Block- Gondlammau, District- Sitapur, State- Uttar Pradesh		

Sample description

Source of Sample	school campus area	Village	Kuchilal
Gram Panchayat	Kuchilal	Block	Gondlammau
District	Sitapur	State	Uttar Pradesh
Address		Remarks	PRIVATE SAMPLE
Latitude		Longitude	

Date & time of sample collection

08.07.2025 | 12:00:00 PM

Date & time of sample received in lab

08.07.2025 | 01:00:00 PM

Date & time of sample analysed

09.07.2025 | 12:27:00 PM

Date & time of report generation

11.07.2025 | 12:29:52 PM


Principal
APS International School
Kuchilal Gopalpur Bhatia Sidhauri
Sitapur

APS International School

Director/Manager

Test results

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Calcium (as Ca)*	mg/l	75	200	7.990	Titration method	
2	Chloride (as Cl)*	mg/l	250	1000	36.000	Argentometric method	
3	Colour*	Hazen units	5	15	0.000	Visual comparison method	
4	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	MFT	
5	Fluoride (as F)*	mg/l	1	1.5	0.200	Ion selective electrode method	
6	Free residual Chlorine	mg/l	0.2	1	0.000	Titration method	
7	Iron (As Fe)*	mg/l	1	No Relaxation	0.110	Phenanthroline method or as per IS 15303 2002 Electrothermal atomic absorption/Spectrophotometer method	
8	Magnesium (As Mg)*	mg/l	30	100	10.690	Calculation by APHA	
9	Nitrate (as NO ₃)*	mg/l	45	No Relaxation	1.760	UV-Visible Spectrophotometer	
10	pH*	NA	6.5-8.5	No Relaxation	7.020	Electrometric method	
11	Sulphate (as SO ₄)*	mg/l	200	400	15.670	Turbidimetric method	
12	TDS*	mg/l	500	2000	112.000	Gravimetric method	
13	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	24.000	Titration method	
14	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	MFT	
15	Total Hardness (As CaCO ₃)*	mg/l	200	600	64.000	EDTA Titrimetric method	
16	Turbidity*	NTU	1	5	0.540	Nephelometric method	

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Data prepared by

Chemist (Niskarsh Tripathi)

Microbiologist (Niskarsh Tripathi)

(Signature)
Principal

APS International School
Kuchlaj Gopalpur Bhatta Sidhauri

Sitapur Jal Jeevan Mission aims at potable tap water supply to every home

Authorised signatory

Ankit Chauhan (Test Lab Incharge)

APS International School

(Signature)
Director